



Product Application Bulletin

This Application Bulletin is for APR Models with changes for the new hot gas pressure setting.

At Rawal Devices, we are constantly looking to improve the APR Control to allow for maximum system performance. With that said we have found that adjusting our factory hot gas setting to start opening to 40 degrees SST (118 PSI) for APR-410 Models -1, -2, -3, -6, -10 rather than the previous setting from 36 degrees SST (109 PSI), allows the APR Control to better match equipment design and thus allowing for optimal performance and dehumidification.

APR Product Update: Models with Changes for New Hot Gas Pressure Setting

APR-410 Models -1, -2, -3, -6, -10 are shipping with new Instructions and a **Green-colored Hang Tag** to denote the new pressure setting.

TIMEFRAME FOR CHANGES

Model #	New Factory Setting	Ship Date
APR-410-1	118 PSI	May
APR-410-2	118 PSI	Mid July
APR-410-3	118 PSI	Mid July
APR-410-6	118 PSI	Mid August
APR-410-10	118 PSI	Mid August

APR Product Update: Model with No Change for New Hot Gas Pressure Setting

The PSI setting on the APR-410-5 will not change. This will remain at the factory setting of 105 PSI with an adjustment range of 95-115 PSI.

Model #	No Change to Factory Setting
APR-410-5	105 PSI

Rawal Technical Support

Whether you're installing the APR on new equipment, upgrading or retrofitting an existing system, Rawal Technical Support can provide the technical application and device expertise you need.

Call us at 800-727-6447 or email at techsupport@rawal.com